

The Department of Energy has published updated energy efficiency metrics for central air conditioners and heat pumps. This publication reflects both the 1987 metric (SEER) and the 2023 metric (SEER2). Efficiency requirements are published at 10 C.F.R. 430.32(c). Please refer to [www.AHRInet.org](http://www.AHRInet.org) for more information about updated energy efficiency metrics.

U.S. Government

Federal law prohibits removal of this label before consumer purchase.

# ENERGYGUIDE

Heat Pump  
Cooling and Heating  
Split System

MRCOOL  
Model DIY-MULTI2-18HP230C




Cooling  
Efficiency Rating (SEER)\*  
**21.00 - 21.00**



Range of Similar Models

\* Seasonal Energy Efficiency Ratio

Heating  
Efficiency Rating (HSPF)\*  
**10.60 - 10.60**



Range of Similar Models

\* Heating Seasonal Performance Factor

For energy cost info, visit  
[productinfo.energy.gov](http://productinfo.energy.gov)

U.S. Government

Federal law prohibits removal of this label before consumer purchase.


# ENERGYGUIDE

Heat Pump  
Cooling and Heating  
Split System

MRCOOL  
Model DIY-MULTI2-18HP230C



Cooling  
Efficiency Rating (SEER2)\*  
**21.20 - 21.20**



Range of Similar Models

\* Seasonal Energy Efficiency Ratio

Heating  
Efficiency Rating (HSPF2)\*  
**9.60 - 9.60**



Range of Similar Models

\* Heating Seasonal Performance Factor

For energy cost info, visit  
[productinfo.energy.gov](http://productinfo.energy.gov)